	E	XHIBI	ΤΑ			
	EQUIVALENT SINGLE-FAMILY DW	ELLING BI	LLING UNIT	FOR RUSSIA	N RIVER CSD	
		Billi	ng Basis		2020-2021	
ı	Use Category	Flow	BOD	TSS	Use	ESD
	,	gallons	mg/l	mg/l		
Residential						
	Single-Family	120	200	200	connections	1.00
	Condominium (Over 900 square ft)	120	200	200	dwelling units	1.00
	Condominium (Under 900 square ft)	96	200	200	dwelling units	0.80
	Multiple-Family (Apts,Duplex/Triplex)	96	200	200	dwelling units	0.80
	Mobile home park	96	200	200	spaces	0.80
	Mobile home (Individual)	96	200	200	units	0.80
	JADU	- 40	200	200	units	0.00
	ADU, under 751 sq ft*	48	200	200	units	
	ADU, 751-900 sq ft* ADU, over 900 sq ft*	96 120	200 200	200 200	units	0.80 1.00
	ADO, over 900 sq it	120	200	200	units	1.00
Commercial						
Commercial	Appliance repair	190	200	200	1,000 sq. ft.	1.58
	Appliance repail Art gallery	190	200	200	1,000 sq. ft.	1.58
	Art gallery Auto dealers	190	200	200	1,000 Sq. It.	1.50
	With service facilities	190	180	280	connection	1.74
	With service facilities With service facilities	38	180	280	add per service bay	0.35
	With service facilities Without service facilities	190	200	280	connection	
		190 38	325	325		1.58 0.45
	Auto repair Bakery	190	1000	600	per service bay 1,000 sq. ft.	4.72
	Beer Making/Brewery	190	1000	see note 1 below		4.72
	Butcher					
	Butcher Banks & financial institutions	190	130	see note 1 below 80	1,000 sq. ft.	1.09
	Barber shop	190	130	80	per chair	0.11
		38	130	80	per chair per chair	0.11
	Beauty shop Bars & taverns	20	200	200		0.22
		20	200	200	per seat	0.17
	Camp ground or RV park	125	200	200	site	1.04
	with hookups	75	200	200	site	0.63
	without hookups	75	200			0.63
	Cannabis production/manufacturing			see note 1 below		1
	Car washes	190	20	150	nor hou	0.00
	manual automatic	125	20 228	150 228	per bay	0.98
		125	220		per bay	1.14
	Cheese Maker Churches, hall & lodges	2	200	see note 1 below 200		0.02
		2			per seat	0.02
	Coffee shops with some food service	6	1000	600	per seat	
	Dry cleaners	285	150	110	1,000 sq. ft.	1.83
	Fire stations	200	205	205	4.000 #	0.50
	with sleeping quarters and kitchens	220	325	325	1,000 sq. ft.	2.59
	without sleeping quarters and kitchens	190	228	228	1,000 sq. ft.	1.73
	Garages	95	180	280	service bays	0.87
	Gas Stations (no other automative services)	70	500	500	1,000 sq. ft.	4.00
	with convenience store	70	520	520		1.20
	without convenience store	38	228	228	1,000 sq. ft.	0.35
	Gym	400	205	205	4.000 #	4 74
	with shower	400	325	325	1,000 sq. ft.	4.71
	without shower	50	228	228	1,000 sq. ft.	0.46
	High Tech Medical Manufacturing			see note 1 below		1
	Hospitals	405	252	100	nor ho -l	
	Convalescent	125	250	100	per bed	0.96
	General	175	250	100	per bed	1.34
	Veterinarian	6	250	100	per cage	0.05
	Hotels/motels	100	310	120	sleeping rooms	0.87
	without restaurant	100	310	120	sleeping rooms	0.87
	B&B/Online Rentals/Vacation Rental homes	100	325	325	per occupant	1.18
	Hydroponic Cultivation (including cannabis)	1.2	228	228	per plant	0.01
	Laundromats				1	
	High efficiency washers	250	228	228	washing machines	2.28
	Regular washers	500	150	110	washing machines	3.20
	Library	190	200	200	1,000 sq. ft.	1.58
	Machine shops	152	180	280	1,000 sq. ft.	1.39
	Markets	38	800	800	1,000 sq. ft.	0.94
	Nail Salon	10	228	228	per seat	0.09
	Offices				4.000 "	
	Business	76	130	80	1,000 sq. ft.	0.43
	Chiropractic Office	190	228	228	Exam. room	1.73
	Dental	190	130	80	Exam. room	1.09
	Medical (clinic)]
	with central handwashing stations	175	325	325	Exam. room	2.00
·	with office, surgery, lab and treatment rooms	190	325	325	Exam. room	2.24
<u></u>	offices with sink	125	325	325	Exam. room	1.47
	offices without sink	100	325	325	Exam. room	1.18
	Veterinarian					
	with office, surgery, and treatment rooms	130	325	325	Exam. room	1.53
	Pet Groomers	260	228	228	1,000 sq. ft.	2.37

LQUIVALLINI SINGLE-FAMIL	QUIVALENT SINGLE-FAMILY DWELLING BILLING UNIT FOR RUSSIAN RIVER CSD Billing Basis 2020-2021					
Use Category	Flow			Use	ESD	
coc suregory	gallons	mg/l	TSS mg/l	000		
Post office	190	130	80	1,000 sq. ft.	1.09	
Resort	· ·	,	see note 1 below			
Restaurants						
Dine-in						
With DW & garbage disp.	6	1000	600	per seat	0.15	
With DW or garbage disp.	6	619	371	per seat	0.10	
Without DW & garbage disp.	6	238	143	per seat	0.05	
Take-out	475	238	143	1,000 sq. ft.	3.83	
Rest homes	125	250	100	per bed	0.90	
Retail stores	38	150	150	1,000 sq. ft.	0.20	
Schools						
Elementary	9	130	100	per student day	0.05	
High	14	130	100	per student day	0.08	
with entertainment facilities	19	325	325	per student day	0.22	
Service stations	380	180	280	set of gas pumps	3.48	
	38	180	280	add per service bay	0.35	
Shoe repair	190	200	200	1,000 sq. ft.	1.58	
Spa with various beauty treatments	38	325	325	per chair	0.4	
Supermarkets	76	325	325	1,000 sq. ft.	0.89	
Tasting Rooms						
Ale, Winery (no food)	120	228	228	1,000 sq. ft.	1.09	
Ale, Winery (with food)	240	520	520	1,000 sq. ft.	4.11	
Theaters	2	200	200	per seat	0.02	
Trash Enclosures			see note 1 below	,		
Warehouse			see note 1 below	/		
Winery			see note 1 below	/		
Others as determined by the Engr.			see note 1 below	/		

ALL COMMERCIAL ESDs TO BE DETERMINED BY THE GENERAL MANAGER USING THE FOLLOWING FORMULA:

ESD = (TSS x FLOW x 0.33)/(SFD TSS x SFD FLOW)+(BOD x FLOW x 0.33)/(SFD BOD x SFD FLOW)+(FLOW x (0.34/SFD FLOW))

Note 1: For non-standard uses, uses and when agreement on a use category cannot be reached, the General Manager, in his or her sole discretion, may

a) base charges on the user's actual or estimated contribution of wastewater into the District's facilities in terms of flow, biological oxygen demand (BOD), and total suspended solids (TSS), and

b) calculate the user's charge using the above Charge Formula. The user shall provide verifiable data, as requested by the General Manager, for the charge to be determined.

Note 2: In general, users with annual average TSS and/or BOD over 1,000 mg/L and users with annual average Flow greater than 5,000 gallons per day should be considered Monitored Users and use the Monitored User Charge Formula.

Е	Definitions	Flow = Gallons per Day			
		BOD = Biological Oxygen Demand	DW = dishwasher		
		ESD = Equivalent Single Family Dwelling	disp = disposal		

* Note that no Capacity Charge is accessed when existing structures are converted in accordance with CGC 65852.2 (e)(1)(A) as determined by the County of Sonoma or the jurisdiction having authority per the Building Code.